



ADDENDUM #2
REQUEST FOR PROPOSALS
No. 2019-020

Effective: July 5, 2019

Project: Vehicle Wash System Design and Build

Issued By: Kevin Etters, Project Manager
City of Gaithersburg
Department of Public Works
800 Rabbitt Road
Gaithersburg, Maryland 20878

This Addendum is incorporated into and made part of the Request for Proposals described above, dated May 31, 2019 ("Solicitation").

The purpose of this Addendum is to publish the questions related to the fire sprinkler system submitted by Bidders in response to the Solicitation and the City's answers thereto. The City is not responsible for the content of the questions and has provided the most comprehensive answers based on the interpretation of the questions.

The following questions were received in writing.

Q 1. Are there any fire protection requirements for the wash system? Tim Holzinger, Haris Design and Construction Co.

A. No, there are no fire protection requirements for the wash system.

Q 2. Will the existing sprinkler system need to be modified to accommodate the wash system? Tim Holzinger, Haris Design and Construction Co.

A. No, the City believes that the existing sprinkler system does not need modified to accommodate the wash system.

~ END OF ADDENDUM ~