



AMENDMENT #1

RFP 2026-033

Effective: May 6, 2026
Solicitation Title: Fuel Facility Replacement
Issued By: City of Gaithersburg
Procurement Division
31 S Summit Avenue
Gaithersburg, Maryland 20877

This Amendment is incorporated into and made part of the above-named Request for Proposal (“Solicitation”). Except as amended herein, all terms and conditions of the Solicitation shall remain unchanged and in full force and effect. The purpose of this Amendment is to change the Solicitation Schedule outlined in section 3.1 and to clarify labor warranty in the specifications document Exhibit B.

1. Section 3.1, subsections D and E are replaced in its entirety with:

D. Addendum Due: May 13, 2026 at 5:00PM
E. Submissions Due: May 21, 2026 at 3:00PM

2. Specifications 231313, Section 1.8 Warranty is replaced in its entirety with:

A. Special Warranty: Manufacturer agrees to repair or replace components of fuel-oil storage tanks that fail in materials or workmanship with the specified warranty period.

1) Storage Tanks:

- a) Failures include, but are not limited to, the following when used for storage of fuel oil at temperatures not exceeding 150 deg F.
 - i. Structural failures including cracking, breakup and collapse
 - ii. Corrosion failure including external and internal corrosion of steel tanks.
- b) Materials Warranty Period: 30 years from date of Substantial Completion.
- c) Labor Warranty Period: 2 years from date of Substantial Completion.

3. Specification 231113 Facility Fuel-Oil Piping, Section 1.10 Warranty, is replaced in its entirety with:

- A. Special Warranty: Manufacturer agrees to repair or replace components of flexible, double-containment piping and related equipment that fail in materials or workmanship within specified warranty period.
 - 1) Failures due to defective materials including piping, dispenser sumps, water-tight sump entry boots, terminations, and other end fittings; Warranty period 10 years from date of Substantial Completion.
 - 2) Labor Warranty Period: 2 years from date of Substantial Completion.

- 4. Specification 262816 Enclosed Switches and Circuit Breakers, Section 1.9 Warranty is replaced in its entirety with:
 - A. Manufacturer's Warranty: Manufacturer and Installer agree to repair or replace components that fail in materials or workmanship within specified warranty period.
 - 1) Warranty Period: One year from date of Substantial Completion.
 - 2) Labor Warranty Period: One year from date of Substantial Completion.

~ END OF AMENDMENT~